



PUBLIC WORKS
Water Division

IEPA - Rockford Regional Office

4302 N. Main St

Rockford, IL 61103

December 5, 2025

Re: Monthly Operating Reports: City of Sycamore – IL0370550

Please find the enclosed operating reports for the City of Sycamore, IL.

- Monthly Operating Reports
- Water Quality Control
- Monthly Chlorine Distribution

Should you have any questions or concerns, please contact me at (815) 895-3545 or by email at maanderson@cityofsycamore.com

Sincerely Yours,

Matt Anderson
City of Sycamore
Director of Public Works

City of Sycamore

Water Division

Monthly Operations Report

2025

DATE	HOURS RUN	PUMPAGE (WELL)	PUMPAGE (FINISHED)	WELL (gpm)	WRT (gpm)	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLUORIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
11/1/2025	24	1,306,000	1,296,000	906.94	900.00	42	3.86	13	0.81	56	0.17
11/2/2025	30	1,870,000	1,945,000	1,038.89	1,080.56	84	5.39	17	0.79	88	0.19
11/3/2025	30	1,784,000	1,820,000	991.11	1,011.11	75	5.04	15	0.77	81	0.19
11/4/2025	31	1,852,000	1,818,000	995.70	977.42	76	4.92	17	0.79	85	0.19
11/5/2025	24	1,393,000	1,442,000	967.36	1,001.39	66	5.68	11	0.76	65	0.19
11/6/2025	28	1,659,000	1,694,000	987.50	1,008.33	68	4.91	17	0.82	78	0.19
11/7/2025	22	1,285,000	1,333,000	973.48	1,009.85	59	5.51	12	0.80	61	0.19
11/8/2025	22	1,287,000	1,287,000	975.00	975.00	52	4.84	11	0.78	60	0.19
11/9/2025	33	1,921,000	1,963,000	970.20	991.41	75	4.68	20	0.83	89	0.19
11/10/2025	27	1,484,000	1,542,000	916.05	951.85	62	5.01	16	0.84	70	0.19
11/11/2025	23	1,391,000	1,413,000	1,007.97	1,023.91	67	5.78	12	0.78	71	0.21
11/12/2025	30	1,725,000	1,770,000	958.33	983.33	71	4.94	17	0.81	78	0.18
11/13/2025	32	1,724,000	1,745,000	897.92	908.85	64	4.45	18	0.83	82	0.19
11/14/2025	21	1,311,000	1,340,000	1,040.48	1,063.49	62	5.67	11	0.77	68	0.21
11/15/2025	21	1,337,000	1,383,000	1,061.11	1,097.62	53	4.75	13	0.81	64	0.20
11/16/2025	25	1,475,000	1,494,000	983.33	996.00	61	4.96	13	0.78	71	0.20
11/17/2025	32	1,866,000	1,923,000	971.88	1,001.56	85	5.46	21	0.85	93	0.20
11/18/2025	35	1,956,000	1,958,000	931.43	932.38	74	4.54	21	0.84	94	0.20
11/19/2025	26	1,579,000	1,657,000	1,012.18	1,062.18	65	4.94	16	0.82	76	0.20
11/20/2025	27	1,503,000	1,495,000	927.78	922.84	55	4.39	15	0.82	68	0.18
11/21/2025	25	1,563,000	1,625,000	1,042.00	1,083.33	73	5.60	14	0.79	73	0.19
11/22/2025	29	1,746,000	1,795,000	1,003.45	1,031.61	76	5.22	19	0.84	81	0.19
11/23/2025	25	1,376,000	1,375,000	917.33	916.67	56	4.88	13	0.80	64	0.19
11/24/2025	30	1,772,000	1,835,000	984.44	1,019.44	81	5.48	16	0.79	82	0.19
11/25/2025	28	1,680,000	1,713,000	1,000.00	1,019.64	67	4.78	18	0.84	77	0.19
11/26/2025	27	1,596,000	1,616,000	985.19	997.53	68	5.11	15	0.80	80	0.20
11/27/2025	27	1,629,000	1,664,000	1,005.56	1,027.16	64	4.71	15	0.79	76	0.19
11/28/2025	23	1,403,000	1,425,000	1,016.67	1,032.61	57	4.87	14	0.82	67	0.19
11/29/2025	26	1,484,000	1,503,000	951.28	963.46	52	4.20	15	0.82	77	0.21
11/30/2025	21	1,318,000	1,339,000	1,046.03	1,062.70	57	5.19	15	0.85	67	0.21
TOTALS											
MONTH	804.0	47,275,000	48,208,000	980.00	999.34	1,967	4.99	460	0.81	2,242	0.19
YEAR	10,453.0	607,999,000	612,264,000	969.42	976.22	24,168	4.77	5,848	0.81	27,285	0.18

Matt Anderson
Water Division

City of Sycamore - Facility #0370550 **WELL 6**

DATE	HOURS RUN	WELL6 RAW	WELL 6 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
11/1/2025	13	642,000	823.08	632,000	810.26	22	4.11	7	0.78	28	0.18
11/2/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/3/2025	9	474,000	877.78	465,000	861.11	16	4.05	4	0.71	20	0.17
11/4/2025	8	449,000	935.42	442,000	920.83	15	4.01	5	0.78	20	0.18
11/5/2025	3	149,000	827.78	147,000	816.67	5	4.02	1	0.66	7	0.19
11/6/2025	9	462,000	855.56	453,000	838.89	16	4.15	5	0.77	21	0.19
11/7/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/8/2025	11	592,000	896.97	582,000	881.82	20	4.05	6	0.75	25	0.17
11/9/2025	12	653,000	906.94	642,000	891.67	22	4.04	7	0.77	30	0.19
11/10/2025	5	228,000	760.00	224,000	746.67	8	4.21	3	0.84	10	0.18
11/11/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/12/2025	12	655,000	909.72	644,000	894.44	22	4.03	6	0.73	29	0.18
11/13/2025	12	610,000	847.22	600,000	833.33	20	3.93	7	0.79	28	0.19
11/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/15/2025	8	448,000	933.33	440,000	916.67	14	3.75	4	0.72	20	0.18
11/16/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/17/2025	7	345,000	821.43	339,000	807.14	11	3.82	4	0.80	15	0.18
11/18/2025	15	820,000	911.11	807,000	896.67	27	3.95	9	0.78	38	0.19
11/19/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/20/2025	14	704,000	838.10	692,000	823.81	24	4.09	7	0.75	32	0.19
11/21/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/22/2025	12	662,000	919.44	651,000	904.17	22	3.98	7	0.77	30	0.18
11/23/2025	11	537,000	813.64	527,000	798.48	18	4.02	6	0.78	25	0.19
11/24/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/25/2025	9	490,000	907.41	483,000	894.44	15	3.67	5	0.76	21	0.17
11/26/2025	4	205,000	854.17	201,000	837.50	6	3.51	2	0.74	10	0.20
11/27/2025	6	341,000	947.22	335,000	930.56	11	3.87	3	0.72	16	0.19
11/28/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/29/2025	7	361,000	859.52	355,000	845.24	11	3.65	4	0.78	16	0.18
11/30/2025	3	163,000	905.56	161,000	894.44	6	4.41	2	0.81	8	0.20
TOTALS											
MONTH	190	9,990,000	876.32	9,822,000	861.58	331	4.04	104	0.87	449	0.19
YEAR	2,945.0	154,101,000	872.11	151,454,000	857.13	5,776	4.57	1,275	0.82	7,156	0.19

City of Sycamore - Facility #0370550

WELL 7

DATE	HOURS RUN	WELL 7 RAW	WELL 7 GPM	Finished PUMPED	Finished GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)	NaMnO4 Usage Gallons	MnSO4 Usage Gallons	Backwash (#)
11/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/2/2025	12	751,000	1,043.06	775,000	1,076.39	38	5.88	6	0.71	40	0.21	0	0	0
11/3/2025	5	353,000	1,176.67	363,000	1,210.00	21	6.94	2	0.65	19	0.21	0.1	0	0
11/4/2025	8	514,000	1,070.83	452,000	941.67	25	6.63	4	0.74	24	0.22	0	0	1
11/5/2025	9	520,000	962.96	534,000	988.89	28	6.29	3	0.65	26	0.20	0	0	0
11/6/2025	1	100,000	1,666.67	101,000	1,683.33	5	5.94	1	0.77	6	0.24	0	0	0
11/7/2025	6	339,000	941.67	348,000	966.67	14	4.82	3	0.74	17	0.20	0	0	0
11/8/2025	5	352,000	1,173.33	362,000	1,206.67	18	5.96	2	0.65	18	0.20	0	0	0
11/9/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/10/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/11/2025	14	883,000	1,051.19	905,000	1,077.38	48	6.36	7	0.71	47	0.21	0	0	0
11/12/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/13/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/14/2025	15	953,000	1,058.89	977,000	1,085.56	49	6.01	7	0.70	50	0.21	0	0	0
11/15/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/16/2025	12	748,000	1,038.89	767,000	1,065.28	35	5.47	6	0.72	39	0.21	0	0	0
11/17/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/18/2025	6	373,000	1,036.11	383,000	1,063.89	21	6.57	3	0.72	19	0.20	0	0	0
11/19/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/20/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/21/2025	8	507,000	1,056.25	519,000	1,081.25	26	6.01	3	0.66	25	0.20	0	0	0
11/22/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/23/2025	6	337,000	936.11	346,000	961.11	18	6.24	3	0.74	17	0.20	0	0	0
11/24/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/25/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/26/2025	12	758,000	1,052.78	777,000	1,079.17	41	6.33	6	0.71	40	0.21	25.9	19.2	0
11/27/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/28/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/29/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	0	0
11/30/2025	15	936,000	1,040.00	959,000	1,065.56	42	5.25	7	0.70	49	0.21	0	0	0
TOTALS														
MONTH	134	8,424,000	1,047.76	8,568,000	1,065.67	429	6.00	63	0.79	436	0.21	26	19.2	1
YEAR	1,321.0	82,170,000	1,036.71	83,537,000	1,053.96	3,810	5.47	623	0.80	4,304	0.21	259	163	10

**City of Sycamore - Facility #0370550
WELL 8**

DATE	HOURS RUN	WELL 8 RAW	WELL 8 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
11/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/2/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/3/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/4/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/5/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/6/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/7/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/8/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/9/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/10/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/11/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/12/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/13/2025	5	230,000	766.67	234,000	780.00	8	4.17	3	0.85	12	0.21
11/14/2025	6	358,000	994.44	363,000	1,008.33	13	4.35	4	0.80	18	0.20
11/15/2025	4	310,000	1,291.67	315,000	1,312.50	12	4.64	3	0.76	16	0.21
11/16/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/17/2025	15	934,000	1,037.78	947,000	1,052.22	45	5.78	10	0.79	48	0.21
11/18/2025	6	302,000	838.89	307,000	852.78	9	3.57	4	0.86	16	0.22
11/19/2025	5	328,000	1,093.33	333,000	1,110.00	10	3.66	4	0.83	16	0.20
11/20/2025	4	254,000	1,058.33	258,000	1,075.00	11	5.19	3	0.82	13	0.21
11/21/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/22/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/23/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/24/2025	7	413,000	983.33	418,000	995.24	15	4.35	4	0.76	21	0.21
11/25/2025	3	213,000	1,183.33	217,000	1,205.56	7	3.94	3	0.88	11	0.21
11/26/2025	6	335,000	930.56	340,000	944.44	9	3.22	4	0.82	17	0.21
11/27/2025	2	104,000	866.67	105,000	875.00	4	4.61	1	0.76	6	0.24
11/28/2025	10	630,000	1,050.00	639,000	1,065.00	22	4.19	7	0.80	32	0.21
11/29/2025	5	320,000	1,066.67	325,000	1,083.33	10	3.75	3	0.75	16	0.20
11/30/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
TOTALS											
MONTH	78	4,731,000	1,010.90	4,801,000	1,025.85	175	4.37	53	0.88	242	0.21
YEAR	2,575.0	167,563,000	1,084.55	169,854,000	1,099.38	6,368	4.50	1,932	0.89	7,230	0.17

Matt Anderson
Water Division

**City of Sycamore - Facility #0370550
WELL 9**

DATE	HOURS RUN	WELL 9 RAW	WELL 9 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
11/1/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/2/2025	10	604,000	1,006.67	655,000	1,091.67	30	5.96	7	0.71	28	0.19
11/3/2025	7	422,000	1,004.76	457,000	1,088.10	21	5.97	4	0.66	20	0.19
11/4/2025	7	412,000	980.95	447,000	1,064.29	21	6.11	4	0.67	20	0.20
11/5/2025	7	432,000	1,028.57	469,000	1,116.67	23	6.38	5	0.71	20	0.19
11/6/2025	8	505,000	1,052.08	548,000	1,141.67	28	6.65	5	0.67	25	0.20
11/7/2025	8	479,000	997.92	518,000	1,079.17	26	6.51	5	0.69	23	0.20
11/8/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/9/2025	10	616,000	1,026.67	669,000	1,115.00	31	6.03	7	0.71	29	0.19
11/10/2025	12	738,000	1,025.00	800,000	1,111.11	35	5.69	8	0.70	37	0.20
11/11/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/12/2025	11	671,000	1,016.67	727,000	1,101.52	33	5.90	7	0.69	31	0.19
11/13/2025	5	316,000	1,053.33	343,000	1,143.33	15	5.69	3	0.66	16	0.21
11/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/15/2025	9	579,000	1,072.22	628,000	1,162.96	27	5.59	6	0.68	28	0.20
11/16/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/17/2025	10	587,000	978.33	637,000	1,061.67	29	5.92	7	0.72	30	0.21
11/18/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/19/2025	14	872,000	1,038.10	945,000	1,125.00	43	5.91	9	0.68	44	0.21
11/20/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/21/2025	10	595,000	991.67	645,000	1,075.00	31	6.25	7	0.72	28	0.19
11/22/2025	11	710,000	1,075.76	770,000	1,166.67	39	6.59	8	0.71	35	0.20
11/23/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/24/2025	11	671,000	1,016.67	729,000	1,104.55	38	6.79	7	0.68	32	0.19
11/25/2025	8	447,000	931.25	483,000	1,006.25	24	6.44	5	0.71	22	0.20
11/26/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/27/2025	7	468,000	1,114.29	508,000	1,209.52	24	6.15	5	0.69	23	0.20
11/28/2025	3	160,000	888.89	173,000	961.11	9	6.74	2	0.74	8	0.20
11/29/2025	4	239,000	995.83	259,000	1,079.17	13	6.52	3	0.74	11	0.19
11/30/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
TOTALS											
MONTH	172	10,523,000	1,019.67	11,410,000	1,105.62	540	5.67	114	0.65	510	0.18
YEAR	668.0	37,967,000	947.28	41,221,000	1,028.47	1,827	5.31	448	0.67	1,703	0.17

**City of Sycamore - Facility #0370550
WELL 10**

DATE	HOURS RUN	WELL 10 RAW	WELL 10 GPM	WRT PUMPED	WRT GPM	CHLORINE (pounds)	CHLORINE (ppm)	FLUORIDE (pounds)	FLOURIDE (ppm)	PHOSPHATE (pounds)	PHOSPHATE (ppm)
11/1/2025	11	664,000	1,006.06	664,000	1,006.06	20	3.61	6	0.71	28	0.17
11/2/2025	8	515,000	1,072.92	515,000	1,072.92	16	3.73	4	0.67	20	0.16
11/3/2025	9	535,000	990.74	535,000	990.74	17	3.81	5	0.72	22	0.17
11/4/2025	8	477,000	993.75	477,000	993.75	15	3.77	4	0.69	21	0.18
11/5/2025	5	292,000	973.33	292,000	973.33	10	4.11	2	0.65	12	0.17
11/6/2025	10	592,000	986.67	592,000	986.67	19	3.85	6	0.74	26	0.18
11/7/2025	8	467,000	972.92	467,000	972.92	19	4.88	4	0.70	21	0.18
11/8/2025	6	343,000	952.78	343,000	952.78	14	4.89	3	0.70	17	0.20
11/9/2025	11	652,000	987.88	652,000	987.88	22	4.05	6	0.71	30	0.19
11/10/2025	10	518,000	863.33	518,000	863.33	19	4.40	5	0.73	23	0.18
11/11/2025	9	508,000	940.74	508,000	940.74	19	4.48	5	0.73	24	0.19
11/12/2025	7	399,000	950.00	399,000	950.00	16	4.81	4	0.74	18	0.18
11/13/2025	10	568,000	946.67	568,000	946.67	21	4.43	5	0.70	26	0.19
11/14/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/15/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/16/2025	13	727,000	932.05	727,000	932.05	26	4.29	7	0.73	32	0.18
11/17/2025	0	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!	0	#DIV/0!
11/18/2025	8	461,000	960.42	461,000	960.42	17	4.42	5	0.76	21	0.19
11/19/2025	7	379,000	902.38	379,000	902.38	12	3.80	3	0.68	16	0.17
11/20/2025	9	545,000	1,009.26	545,000	1,009.26	20	4.40	5	0.71	23	0.17
11/21/2025	7	461,000	1,097.62	461,000	1,097.62	16	4.16	4	0.70	20	0.18
11/22/2025	6	374,000	1,038.89	374,000	1,038.89	15	4.81	4	0.75	16	0.17
11/23/2025	8	502,000	1,045.83	502,000	1,045.83	20	4.78	4	0.68	22	0.18
11/24/2025	12	688,000	955.56	688,000	955.56	28	4.88	5	0.66	29	0.17
11/25/2025	8	530,000	1,104.17	530,000	1,104.17	21	4.75	5	0.72	23	0.18
11/26/2025	5	298,000	993.33	298,000	993.33	12	4.83	3	0.74	13	0.18
11/27/2025	12	716,000	994.44	716,000	994.44	25	4.19	6	0.69	31	0.18
11/28/2025	10	613,000	1,021.67	613,000	1,021.67	26	5.09	5	0.68	27	0.18
11/29/2025	10	564,000	940.00	564,000	940.00	18	3.83	5	0.70	34	0.25
11/30/2025	3	219,000	1,216.67	219,000	1,216.67	9	4.93	6	1.22	10	0.19
TOTALS											
MONTH	230	13,607,000	986.01	13,607,000	986.01	492	4.34	126	0.84	605	0.18
YEAR	2,944.0	166,198,000	940.89	166,198,000	940.89	6,387	4.61	1,570	0.84	6,892	0.17

Matt Anderson
Water Division

City of Sycamore
Distribution Chlorine Residuals
Facility #0370550



	Area #1		Area #2		Area # 3		Tower #1		
Date	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Total Chlorine	Free Chlorine	Comments
11/1/2025							0.91	0.80	
11/2/2025							0.97	0.83	
11/3/2025	1.10	0.97	2.6	1.70	1.4	1	0.84	0.78	
11/4/2025	1.14	1.07	2.4	2.00	1.1	0.98	1.01	0.93	
11/5/2025	1.16	1.00	1.59	1.36	0.69	0.53	0.93	0.80	
11/6/2025	1.10	0.96	1.64	1.49	0.71	0.64	0.92	0.84	
11/7/2025	1.43	1.24	1.78	1.56	1.51	1.39	0.94	0.85	
11/8/2025							0.98	0.82	
11/9/2025							0.82	0.72	
11/10/2025	1.12	1.07	1.31	1.18	1.56	1.41	0.93	0.77	
11/11/2025							0.89	0.79	Holiday
11/12/2025	1.33	1.11	1.7	1.50	1.16	1.02	0.88	0.75	
11/13/2025	1.09	0.98	1.6	1.43	1.47	1.29	0.79	0.70	
11/14/2025	1.00	0.96	1.5	1.20	1.11	1.07	1.01	0.92	
11/15/2025							1.26	1.02	
11/16/2025							1.3	1.11	
11/17/2025	1.10	0.95	1.22	1.15	0.95	0.78	1.26	1.15	
11/18/2025	1.14	1.01	1.5	1.10	1.24	1.14	1.4	1.20	
11/19/2025	1.30	1.10	0.95	0.80	0.93	0.73	1.26	1.05	
11/20/2025	0.83	0.71	1.09	0.97	1.01	0.9	1	0.94	
11/21/2025	1.02	0.89	1.3	1.12	0.71	0.6	1.11	1.02	
11/22/2025							1.36	1.20	
11/23/2025							1.31	1.14	
11/24/2025	1.28	1.08	1.33	1.12	1.08	0.93	1.25	1.07	
11/25/2025	1.07	0.97	1.29	1.09	1.03	0.84	1.21	1.05	
11/26/2025	1.06	0.89	1.15	1.00	1.06	0.94	1.31	1.05	
11/27/2025							1.4	1.01	Holiday
11/28/2025							1.24	1.15	Holiday
11/29/2025							1.32	1.16	
11/30/2025							1.3	1.13	

WELL 6
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
11/1/2025	1.4	0.80	0.40	
11/2/2025	1.2	0.80	0.59	
11/3/2025	1.6	0.90	0.48	
11/4/2025	1.4	0.80	0.66	
11/5/2025	1.3	0.90	0.60	
11/6/2025	1.2	0.80	0.49	
11/7/2025	1.3	0.80	0.70	
11/8/2025	1.0	0.90	0.66	
11/9/2025	1.7	0.80	0.83	
11/10/2025	1.2	0.90	0.47	
11/11/2025	1.4	0.80	0.51	
11/12/2025	1.4	0.80	0.54	
11/13/2025	1.5	0.80	0.44	
11/14/2025	1.2	0.70	0.46	
11/15/2025	1.0	0.80	0.45	
11/16/2025	1.0	0.90	0.40	
11/17/2025	1.6	0.80	0.47	
11/18/2025	1.9	1.00	0.67	
11/19/2025	4.3	1.00	0.80	
11/20/2025	1.0	0.90	0.53	
11/21/2025	1.0	0.80	0.78	
11/22/2025	1.2	1.00	0.34	
11/23/2025	1.7	0.90	0.55	
11/24/2025	2.3	0.60	0.32	
11/25/2025	1.3	0.70	0.51	
11/26/2025	1.1	0.60	0.68	
11/27/2025	1.4	0.80	0.48	
11/28/2025	1.4	0.80	0.67	
11/29/2025	1.0	0.70	0.54	
11/30/2025	1.0	1.00	0.79	

WELL 7
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Iron Raw	Iron Finished	Manganese Raw	Manganese Finished	Initials
11/1/2025	1.3	0.70	0.70	NR	0.01	NR	0.02	
11/2/2025	1.7	0.70	0.74	NR	0.02	NR	0.03	
11/3/2025	2.9	0.90	0.64	0.35	0.11	0.02	0.01	
11/4/2025	2.9	0.90	0.32	0.45	0.04	0.03	0.20	
11/5/2025	3.2	0.70	0.69	NR	0.01	NR	0.02	
11/6/2025	2.7	0.70	0.33	0.29	0.05	0.02	0.01	
11/7/2025	2.2	0.80	0.49	NR	0.00	NR	0.02	
11/8/2025	2.4	0.90	0.76	NR	0.00	NR	0.03	
11/9/2025	1.4	0.80	0.87	NR	0.00	NR	0.06	
11/10/2025	2.3	0.90	0.32	0.26	0.00	0.01	0.04	
11/11/2025	3.1	0.80	0.87	NR	0.00	NR	0.03	
11/12/2025	2.7	0.70	0.64	NR	0.00	NR	0.04	
11/13/2025	1.8	0.90	0.83	NR	0.02	NR	0.03	
11/14/2025	2.4	0.90	0.54	NR	0.14	NR	0.03	
11/15/2025	1.6	0.70	0.63	NR	0.19	NR	0.03	
11/16/2025	2.3	0.90	0.50	NR	0.08	NR	0.04	
11/17/2025	3.1	1.00	0.93	NR	0.06	NR	0.02	
11/18/2025	2.1	0.80	0.55	NR	0.00	NR	0.02	
11/19/2025	3.7	0.70	0.76	0.30	0.06	0.02	0.02	
11/20/2025	3.0	0.70	0.49	0.17	0.07	0.03	0.02	
11/21/2025	2.4	0.80	0.59	NR	0.04	NR	0.03	
11/22/2025	1.9	1.00	0.96	NR	0.05	NR	0.02	
11/23/2025	2.6	0.70	0.44	NR	0.03	NR	0.02	
11/24/2025	2.5	1.00	0.32	NR	0.00	NR	0.02	
11/25/2025	2.9	0.90	0.41	0.31	0.08	0.02	0.03	
11/26/2025	2.3	0.80	0.57	NR	0.04	NR	0.03	
11/27/2025	1.8	0.90	0.59	NR	0.06	NR	0.02	
11/28/2025	1.6	0.90	0.81	NR	0.03	NR	0.02	
11/29/2025	1.9	0.80	0.47	NR	0.03	NR	0.02	
11/30/2025	2.4	0.80	0.45	NR	0.04	NR	0.02	

WELL 8

Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
11/1/2025				
11/2/2025				
11/3/2025				
11/4/2025				
11/5/2025				
11/6/2025				
11/7/2025				
11/8/2025				
11/9/2025				
11/10/2025				
11/11/2025				
11/12/2025				
11/13/2025	4.3	0.80	0.29	
11/14/2025	1.8	0.80	0.32	
11/15/2025	1.0	0.80	0.30	
11/16/2025	0.8	0.70	0.44	
11/17/2025	1.9	0.70	0.62	
11/18/2025	1.7	0.80	0.68	
11/19/2025	4.9	0.70	0.48	
11/20/2025	2.3	0.70	0.58	
11/21/2025	1.0	0.70	0.45	
11/22/2025	0.9	0.70	0.56	
11/23/2025	0.8	0.80	0.66	
11/24/2025	1.8	0.70	0.77	
11/25/2025	1.7	0.80	0.67	
11/26/2025	3.2	0.80	0.45	
11/27/2025	1.5	0.80	0.61	
11/28/2025	1.0	0.80	0.55	
11/29/2025	1.3	0.70	0.69	
11/30/2025	1.5	0.70	0.68	

WELL 9
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
11/1/2025	1.7	0.70	0.68	
11/2/2025	2.8	1.00	0.56	
11/3/2025	2.3	0.90	0.59	
11/4/2025	2.4	0.80	0.68	
11/5/2025	2.3	1.00	0.58	
11/6/2025	2.6	1.00	0.76	
11/7/2025	3.8	1.00	0.88	
11/8/2025	5.2	0.60	0.97	
11/9/2025	1.3	0.70	0.76	
11/10/2025	5.0	0.90	1.00	
11/11/2025	1.6	0.80	0.83	
11/12/2025	1.7	0.70	0.59	
11/13/2025	1.2	0.80	0.55	
11/14/2025	1.0	0.70	0.51	
11/15/2025	1.2	0.90	0.60	
11/16/2025	1.1	0.80	0.77	
11/17/2025	4.5	1.00	0.78	
11/18/2025	1.0	1.00	0.78	
11/19/2025	5.3	0.70	0.62	
11/20/2025	1.7	0.70	0.93	
11/21/2025	3.9	1.00	0.91	
11/22/2025	4.8	0.90	0.90	
11/23/2025	1.1	0.80	0.60	
11/24/2025	4.7	0.80	0.78	
11/25/2025	2.1	0.90	0.80	
11/26/2025	1.6	0.90	0.78	
11/27/2025	1.6	0.80	0.72	
11/28/2025	1.6	0.90	0.48	
11/29/2025	1.3	0.80	0.79	
11/30/2025	1.1	0.90	0.70	

WELL 10
Water Quality Control

Date	Total Chlorine	Fluoride	Phosphate	Initials
11/1/2025	1.8	0.70	0.44	
11/2/2025	1.3	0.70	0.47	
11/3/2025	2.8	0.80	0.51	
11/4/2025	3.8	0.80	0.34	
11/5/2025	1.5	0.70	0.49	
11/6/2025	3.7	0.80	0.28	
11/7/2025	1.0	0.80	0.33	
11/8/2025	1.0	0.70	0.59	
11/9/2025	1.0	0.70	0.29	
11/10/2025	0.9	0.80	0.25	
11/11/2025	1.1	0.70	0.39	
11/12/2025	0.9	0.80	0.50	
11/13/2025	1.0	0.78	0.40	
11/14/2025	0.9	0.70	0.48	
11/15/2025	0.8	0.80	0.51	
11/16/2025	1.2	0.80	0.60	
11/17/2025	0.9	0.90	0.79	
11/18/2025	1.4	0.90	0.69	
11/19/2025	4.6	0.80	0.46	
11/20/2025	0.9	0.70	0.45	
11/21/2025	0.9	1.00	0.71	
11/22/2025	1.0	0.90	0.39	
11/23/2025	1.1	0.90	0.60	
11/24/2025	0.9	1.00	0.66	
11/25/2025	0.9	0.90	0.42	
11/26/2025	0.8	0.80	0.43	
11/27/2025	3.6	1.00	0.53	
11/28/2025	1.0	0.90	0.29	
11/29/2025	0.9	0.90	0.70	
11/30/2025	0.8	1.00	0.67	